

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No: WSC/2197/24

Dated: 18/07/2024

It is certified that an inspection team headed by DR. CHANDRA PAL SINGH, Consultant MD (Name of Officers with designation) from Distt. Combind Hospital, Amroha inspected the Victoria Public School, Amroha (Name & Address of the school) on 18/7/2024 (date of inspection) and on the basis of Water Test Report (Attached) bearing no DW/0724/1013 dated 10/07/2024 of SPECTRA TESTING LABS(OPC) PVT. LTD.(PHED Lab) certified that the VICTORIA PUBLIC SCHOOL, AMROHA has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid for a period of one year.

18-07-2024
DR CHANDRA PAL SINGH
DR. CHANDRA PAL SINGH
CONSULTANT MD (PHYSICIAN)
Reg. - 54538
Distt. Combind Hospital, Amroha

Signature with Seal:
Name: D.R. CHANDRA PAL SINGH
Designation: CONSULTANT MD
Name & Address of the Office/Department:
DISTT. COMBIND HOSPITAL
AMROHA

To,

Principal, Victoria Public School
Bijnor Road, Amroha,
Uttar Pradesh 244221
(Name & Address of the Institution)

Gitayali
Principal
Victoria Public School
Amroha

Sh
Manager
Victoria Public School
Bijnor Road, Amroha



SPECTRA TESTING LABS(OPC) PVT.LTD.

THE RESULT YOU CAN TRUST

(FORMERLY KNOWN AS SPECTRA ANALYTIC LAB)

(An ISO 9001:2015, 14001:2015, OHSAS 45001:2018 Certified Company & NABL Accredited Laboratory)

Plot No :- 343/14, Krishna Colony, Sehatpur, Faridabad, Haryana-121003

Email: care.spectra@gmail.com | Website: www.spectraanalyticlabs.com | 9560653541, 9310207829

TEST REPORT

Name & Address of Customer		Test Report Number	DW/0724/10130
ISSUED TO:- M/S VICTORIA PUBLIC SCHOOL BIJNOR ROAD AMROHA, TEHSIL & DISTRICT AMROHA UP 244221		Date of Report	10.07.2024
		Job Order Number	SAL/ DW/0724/03130
		Sample Description	One Sample of Water
		Date of Sampling	02.07.2024
		Sampling Done by	SAL Lab Representative
		Sample Location	Water Sample
		Sampling Protocol	IS: 3025 (Part-01)
Sample Received on	03.07.2024	Sample Quantity	1 Ltr + 500 ml
Analysis Start Date	03.07.2024	Sample Packing	Plastic Bottle
Analysis End Date	10.07.2024	Sample Marking	Water Sample

TEST RESULTS

WATER SAMPLE ANALYSIS REPORT

S. No	Parameters	Unit	Max Requirement as per (IS-10500-2012) Ammn.2		Results	Test Method
			Acceptable	Permissible (in absence of alternate source)		
Physico-Chemical						
1.	True Color	Hazen	5	15	<5	IS: 3025(Part-04)1983 RA2017
2.	Turbidity	NTU	1	5	<1	IS: 3025(Part-10)1984 RA 2017
3.	pH Value at 25°C	-	6.5-8.5	No Relaxation	7.30	IS: 3025(Part-11)1983 RA 2017
4.	Total Hardness (as CaCO ₃)	mg/l	200	600	25.0	IS: 3025(Part-21)2009 RA 2019
5.	Total Alkalinity as CaCO ₃	mg/l	200	600	48.0	IS: 3025(Part-23)1986 RA 2019
6.	Total Dissolved Solids	mg/l	500	2000	94.0	IS: 3025(Part-16)1984 RA 2017
7.	Chlorides (as Cl)	mg/l	250	1000	14.9	IS: 3025(Part-32)1988 RA 2019
8.	Calcium(as Ca)	mg/l	75	200	8.0	IS: 3025(Part-40)1991 RA 2019
9.	Magnesium (as Mg)	mg/l	30	100	2.7	IS: 3025 (Part-46)1994 RA2019
10.	Sulphate (as SO ₄)	mg/l	200	400	2.6	IS: 3025(Part-24)1986 RA 2019
11.	Iron (as Fe)	mg/l	0.3	No Relaxation	0.04	IS: 3025(Part-53)2003 RA 2019
12.	Fluoride (as F)	mg/l	1	1.5	0.05	IS: 3025(Part-60)2008 RA 2019
13	Total Coliform, MPN per 100ml	Shall not be detectable in any 100ml sample	Absent		IS:15185	
14	E. Coli, per 100ml				Absent	

***End of Report**

Chandra Dev

(Sr. Chemist)

Analyst

NOTE:

- The Results given above are related to the tested sample, as received & mentioned parameters. The Customer Asked For the above tests only.
- Responsibility of the Laboratory is Limited to the Invoiced Amount only.
- This test report will not be generated again, either wholly or in part, without Prior Written Permission of the Laboratory.
- This test report will not be used for any Publicity/legal Purpose.
- The test samples will be disposed off after two weeks from the date of issue of test report, unless until specified by the customer.
- This is Computer Generated Report does not Require Physical Delivery

Manager
Victoria Public School

Ambika Rawat

(Quality Manager)

Checked by

Omesh Kumar

(Technical Manager)

AUTHORISED SIGNATORY

Principal

Victoria Public School

Amroha

Format No. SAL/7.8-01 Issue no.01 issue Date 05.01.2021 Rev.No.26.10.2023